

Test Certificate

for tests according to DIN EN 253:2020-03

on preinsulated pipe system

“PREMANT DN50, Ø 60,3/125 mm”

Manufacturer: Brugg Rohrsystem AG
Production site: Industriestrasse 39
5314 Kleindöttingen
SWITZERLAND
Type of sample: Preinsulated pipe system PREMANT DN50, Ø 60,3/125 mm
Service pipe: Steel P235GH 60,3 x 2,9 mm
Insulation: PUR
Casing: HDPE 125 x 3,0 mm
Delivery of samples: 2022-05-24
Sampling by: by customer
Test report number: V184/22.1 and V184/22.2
Tested characteristics: Thermal conductivity with 0,0257 W/(m*K)
Closed cell content
Foam density
Water absorption,
Test result: The preinsulated pipe system PREMANT DN50, Ø 60,3/125 mm fulfilled the requirements of DIN EN 253 with the tested characteristics.

IMA Materialforschung und Anwendungstechnik GmbH

Wilhelmine-Reichard-Ring 4
01109 Dresden

Dresden, 2024-02-05

Place, Date




Head of Department Pipe Systems
and Construction Products

Dipl.-Ing. Mathias Kessenich