

CERTIFICATE OF COMPLIANCE

Certificate Number MH45398
Report Reference MH45398-20070920
Issue Date 2020-SEPTEMBER-08

Issued to: BRUGG Rohrsysteme GmbH
Adolf-Osterheld-Strasse 31
31515 Wunstorf GERMANY

**This certificate confirms that
representative samples of**

PIPING, FLAMMABLE LIQUID, UNDERGROUND
Complementary Product Category ABOVEGROUND
PIPING FOR FLAMMABLE AND COMBUSTIBLE LIQUIDS
See next page

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/CAN/UL/ULC - Aboveground Piping for Flammable
and Combustible Liquids

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number MH45398
Report Reference MH45398-20070920
Issue Date 2020-SEPTEMBER-08


This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Models

USL, CNL – Metallic Underground Piping for Flammable Liquids – FLEXWELL – 1/2, 1, 1-1/2, 2 and 3 in. diameter, Secon X and Secon X II – 1, 1-1/2, 2, 2-1/2, and 3 inch diameter Flexible Type Piping for use as Integral Primary/Secondary Pipe System (PS) for underground fuel transfer applications such as gas stations for Motor Vehicle (MV), High Blend (HB), Concentrated (CT) and Aviation and Marine (A&M) Fuels.

COMPLEMENTARY LISTING:

USL, CNL –Secondary Containment Aboveground Pipe for Flammable and Combustible Liquids - FLEXWELL – 1/2, 1, 1-1/2, 2 and 3 in. diameter for General-use Fuels, B100 and DEF with 2 hour fire rating and Marine Use.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

