

Product Conformity

according to AGFW FW 420-1:2011-12
on the preinsulated flexible pipe system

„FLEXSTAR“

Manufacturer:	BRUGG Rohrsystem AG
Production site:	Industriestr. 39 CH-5314 Kleindöttingen SWITZERLAND
Specimens:	Preinsulated flexible pipe system FLEXSTAR 63/105 mm Service pipe: PEXa Insulation: PUR Casing: LLDPE
Delivery of samples:	2025-12-09, sampling by customer
Test report number:	V702/25
Tested characteristics:	Linear water tightness, class A
Test result:	The preinsulated flexible pipe system with PUR foam insulation fulfilled the requirements of AGFW FW 420-1 with the tested characteristics.

IMA Materialforschung und Anwendungstechnik GmbH
Am Lagerplatz 4
01099 Dresden

Dresden, 2026-04-20

Place, Date



Dipl.-Ing. Mathias Kessenich

Applus⁺ IMA Materialforschung und
Applicationstechnik GmbH
Head of Department
Pipe Systems and
Construction Products
Am Lagerplatz 4
01099 Dresden / Germany